

## SUMMARY REPORTS FOR MUNICIPALITIES

### Report

This report is a summary of water quality information for the Killaloe Water Treatment Facility, published in accordance with Schedule 22 of Ontario's Drinking-Water Systems Regulation for the reporting period of January 1, 2005 to December 31, 2005. The Killaloe Water Treatment Plant is categorized as a Large Municipal Residential Drinking Water System.

This report was prepared by The Ontario Clean Water Agency on behalf of the Township of Killaloe, Hagarty and Richards.

### Who gets a copy of the Report:

- in the case of a drinking-water system owned by a municipality, the members of the municipal council;

### What must the Report contain?

The report must,

- (a) list the requirements of the Act, the regulations, the system's approval and any order that the system **failed to meet** at any time during the period covered by the report and specify the duration of the failure; and
- (b) for each failure referred to in clause (a), describe the measures that were taken to correct the failure.

The following table lists the requirements that the system failed to meet and the measures taken to correct the failure:

Drinking Water Legislation	List the requirement(s) the system failed to meet	Specify the duration of the failure (i.e. date(s))	Describe the measures taken to correct the failure	Status (complete or outstanding)
Certificate of Approval	Operations and maintenance manuals to be updated	July 19, 2005	Updated operations manual to include all information as set out in Certificate of Approval.	Complete
	Raw water flow exceeded 418 L/min	October 17, 2005	Discussed with inspector and adjusted flow control valve accordingly.	Complete
170/03	AWQI – TC 3cfu/100ml in distribution	July 21, 2005	Re-sampled	Complete
	Reporting AWQI timeline.	July 19, 2005	Reviewed procedure for reporting AWQI	Complete

	Recording distribution chlorine residuals	July 19, 2005	Review procedure.	Complete
--	---	---------------	-------------------	----------

**What else must the Report contain?**

The report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system:

1. A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows and daily instantaneous peak flow rates.
2. A comparison of the summary referred to in paragraph 1 to the rated capacity and flow rates approved in the system’s approval.

Attached please find a copy of the Annual Record of Water Taking for the Killaloe Water Treatment Facility that contains all required flow information.

**When Does the Report Get Submitted?**

If a report is prepared for a system that supplies water to a municipality under the terms of a contract, the owner of the system shall give a copy of the report to the municipality by March 31.

End