

SUMMARY REPORTS FOR MUNICIPALITIES

Report

This report is a summary of water quality information for the Killaloe Water Treatment Facility, published in accordance with Schedule 22 of Ontario's Drinking-Water Systems Regulation for the reporting period of January 1, 2003 to December 31, 2003. The Killaloe Water Treatment Facility is categorized as a Large Municipal Residential Drinking Water System.

This report was prepared by the Ontario Clean Water Agency on behalf of Township of Killaloe, Hagarty & Richards.

Who gets a copy of the Report:

- in the case of a drinking-water system owned by a municipality, the members of the municipal council;

What must the Report contain?

The report must,

- (a) list the requirements of the Act, the regulations, the system's approval and any order that the system **failed to meet** at any time during the period covered by the report and specify the duration of the failure; and
- (b) for each failure referred to in clause (a), describe the measures that were taken to correct the failure.

The following table lists the requirements that the system failed to meet and the measures taken to correct the failure:

Drinking Water Legislation	List the requirement(s) the system failed to meet	Specify the duration of the failure (i.e. date(s))	Describe the measures taken to correct the failure	Status (complete or outstanding)
Certificate of Approval 5808-548K4T	Treated Water THM sample missed.	3 rd quarter	A Sample Calendar has been developed, reviewed with staff and implemented.	Complete
Provincial Officer's Order P805-010905-01	Selenium sampling on Raw, Treated and Distribution water missed	2 nd and 3 rd quarter	A Sample Calendar has been developed, reviewed with staff and implemented.	Complete
Safe Drinking Water Act: Section 18 O. Reg. 170/03: Schedule 16.	Failure to report THM exceedances (rolling annual average) for treated and distribution samples	2003	A Standard Operating Procedure has been developed, reviewed with staff and implemented.	Complete
Permit To Take Water Number 91-P-4041	Pumping Rate > 418 L/minute.	2003	Application has been made to the MOE requesting an increase to the pumping rate limit.	Outstanding

SUMMARY REPORTS FOR MUNICIPALITIES

What else must the Report contain?

The report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system:

1. A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows and daily instantaneous peak flow rates.
2. A comparison of the summary referred to in paragraph 1 to the rated capacity and flow rates approved in the system's approval.

Attached please find a copy of the Annual Record of Water Taking for the Killaloe Water Treatment Facility. This document contains all required flow information.

When Does the Report Get Submitted?

If a report is prepared for a system that supplies water to a municipality under the terms of a contract, the owner of the system shall give a copy of the report to the municipality by March 31.

End