

Killaloe Drinking Water System

Waterworks # 220006026
System Category – Large Municipal Residential

Annual Water Report

Prepared For: Township of Killaloe, Hagarty and Richards



Reporting Period of January 1st – December 31st 2021

Issued: February 28th, 2022

Revision: 0

Operating Authority:



This report has been prepared to satisfy the annual reporting requirements in O.Reg 170/03 Section 11 and Schedule 22

Table of Contents

Report Availability	1
Compliance Report Card	1
System Process Description.....	1
Raw Source	1
Treatment.....	2
Distribution.....	2
Treatment Chemicals used during the reporting year:.....	2
Summary of Non-Compliance.....	3
Adverse Water Quality Incidents.....	3
Non-Compliance	3
Non-Compliance Identified in a Ministry Inspection:.....	3
Flows.....	4
Raw Water Flows.....	4
Total Monthly Flows.....	4
Monthly Rated Flows	4
Treated Water Flows	5
Monthly Rated Flows	5
Annual Total Flow Comparison	5
Regulatory Sample Results Summary	6
Microbiological Testing.....	6
Operational Testing	6
Inorganic Parameters	6
Schedule 15 Sampling:.....	7
Organic Parameters.....	7
BTEX Parameters.....	9
Additional Legislated Samples.....	10
Evaluation of the Effectiveness of Secondary Disinfectant	11
Major Maintenance Summary.....	11
WTRS Data and Submission Confirmation	A

Report Availability

The annual report will be available to residents at the Township of Killaloe, Hagarty and Richards Municipal Office and copies provided free of charge if requested. The Township of Killaloe, Hagarty and Richards Municipal Office is located at, 1 John Street, Killaloe, Ontario.

There are no additional drinking water systems that receive water from this facility.

Compliance Report Card

Compliance Event	# of Events
Ministry of Environment Inspections	1 MECP Inspection on September 14 th 2021 96.54% Rating
Ministry of Labour Inspections	0
QEMS External Audit	1 Audit completed on January 11 th 2021 by SAI Global. No major or minor non-conformances were identified.
AWQI's/BWA	0/0
Non-Compliance	4
Community Complaints	0
Spills	0
Watermain Breaks	0

System Process Description

Raw Source

The Killaloe DWS drinking water is drawn from a ground water production well. The well is located approximately 33 m east of the treatment plant at 226 Water Street in Killaloe Ontario, in a prefabricated steel building. The well was drilled in 1989, measuring 200 mm in diameter, 56 m deep and is equipped with a submersible pump rated at 418 L/min at a total dynamic head (TDH) of 57.5 metres.

Treatment

Groundwater is directed to the treatment plant through a 100 mm diameter discharge line where sodium hypochlorite is added to aid in the primary disinfection process. The water then flows through a dual media Green Sand Contactor for iron and manganese removal. Potassium permanganate is added to assist in the recharging of the greensand contactor. The water is then directed to a pair of UV disinfection systems (one duty, one standby) to achieve CT. Prior to entering the clearwells, stabilized hydrogen peroxide is added to achieve secondary disinfection.

Treated water is discharged into a clear well with a total storage 620 m³, Five high lift pumps consisting of 3 vertical turbine pumps, one vertical turbine fire pump and one vertical turbine jockey pump provide water to the distribution system. Two 1400 L hydropneumatic pressure tanks maintain distribution system pressure and provide some storage.

The backwash wastewater and filter to waste water from the green sand contactor discharges into a wastewater 75 m³ settling pond located 20 metres southwest of the treatment plant.

Distribution

This Class 1 Water Distribution system supplies treated water to an estimated of population of 660 people. The distribution system consists of an assortment of plastic piping. Various valves are installed on the distribution lines to allow for isolation and flow direction control. The distribution piping runs as far north as Mill Street, east as Coll Street, south as Cameron Street and west as Angus Street. 12 fire hydrants are located throughout the distribution system.

Treatment Chemicals used during the reporting year:

Chemical Name	Use	Supplier
Potassium Permanganate (granular 97.5%)	Manganese Control	Cariox via Brenntag
Sodium Hypochlorite (12%)	Disinfection	Brenntag
Hydrogen Peroxide (Huwa San)	Disinfection	San Eco Tech
Hydrogen Peroxide (Huwa San)	Disinfection	Arbourdale

Summary of Non-Compliance

Adverse Water Quality Incidents

Date	AWQI #	Location	Problem	Details	Legislation	Corrective Action Taken
None to report.						

Non-Compliance

Legislation	requirement(s) system failed to meet	duration of the failure (i.e. date(s))	Corrective Action	Status
MDWL	Monthly Backwash Wastewater samples for Suspended Solids, pH, and Total Chlorine Residual were not collected	March 2021	Operations staff received training on the sampling procedures and responsibilities specific to the facility	Complete
O.Reg 170/03	No Trihalomethanes, Haloacetic acids, Nitrate, and Nitrite samples were collected during the quarter	Q1: January – March 2021	Operations staff received training on the sampling procedures and responsibilities specific to large municipal residential systems	Complete
O.Reg 170/03	Microbiological distribution samples were not collected on a weekly basis	June 8 th – June 21 st 2021	June 15 th 2021 samples were not received due to a courier error. SGS laboratories now emails OCWA when coolers are received, should a courier error happen resampling can happen within the weekly sampling period	Complete
MDWL	Backwash Wastewater Total Chlorine Residual Annual Average Concentration exceeded 0.02 mg/L	2021	A single sample collected in February 2021 caused the exceedance	Complete

Non-Compliance Identified in a Ministry Inspection:

Legislation	requirement(s) system failed to meet	duration of the failure (i.e. date(s))	Corrective Action	Status
None to report.				

Flows


The Killaloe Drinking Water System is operating on average under half the rated capacity.

Raw Water Flows

The Raw Water flows are regulated under the Permit to Take Water (PTTW). 2021 Raw Flow Data was submitted to the Ministry electronically under permit #2835-9LMRUZ. The confirmation and a copy of the data that was submitted are attached in Appendix A.


Total Monthly Flows

Max Allowable - PTTW



Monthly Rated Flows

Max Allowable Rate - PTTW




Treated Water Flows


The Treated Water flows are regulated under the Municipal Drinking Water Licence (MDWL).

Monthly Rated Flows

Rated Capacity - MDWL



Annual Total Flow Comparison



Regulatory Sample Results Summary

Microbiological Testing

	No. of Samples Collected	Range of E.Coli Results		Range of Total Coliform Results		Range of HPC Results	
		Min	Max	Min	Max	Min	Max
Raw Water	51	0	0	0	0	N/A	N/A
Treated Water	51	0	0	0	0	0	10
Distribution Water	110	0	0	0	0	0	22

NOTE: 52 samples were collected in 2021 but samples collected on June 15th 2021 samples were not received by the laboratory due to a courier error.

Operational Testing

	No. of Samples Collected	Range of Results	
		Minimum	Maximum
Turbidity, In-House (NTU) - RW	155	0.14	0.51
Turbidity, In-House (NTU) - TW	244	0.09	0.29
Free Chlorine Residual, In-House (mg/L) - TW	139	0.56	0.99
Free Chlorine Residual, On-Line (mg/L) - TW	8760	0.55	1.00
Post Clearwell Peroxide Residual, On-Line (mg/L) - TW	8760	2.38	15.95
Distribution Peroxide Residual, In-House (mg/L) - DW	209	1.00	7.80
Distribution Peroxide Residual, On-Line (mg/L) - DW	8760	1.99	8.23
Distribution pH, In-House - DW	52	7.01	7.86
UV Transmittance (%) - RW	49	85	86.2

NOTE: spikes recorded by on-line instrumentation were a result of air bubbles and various maintenance/calibration activities. All spikes are reviewed for compliance with O.Reg 170/03

Inorganic Parameters

These parameters are tested as a requirement under O. Reg. 170/03. Sodium and Fluoride are required to be tested every 60 months. Nitrate and Nitrite are tested quarterly and metals are tested annually as required under O. Reg. 170/03. In the event any parameter exceeds half the maximum allowable concentration the parameter is required to be sampled quarterly.

- MAC = Maximum Allowable Concentration as per O. Reg. 169/03
- <MDL = Less than Method Detection Limit

	Sample Date (yyyy/mm/dd)	Sample Result	MAC	No. of Exceedances	
				MAC	1/2 MAC
Treated Water					
Antimony: Sb (ug/L) - TW	2021/01/11	<MDL 0.9	6.0	No	No
Arsenic: As (ug/L) - TW	2021/01/11	<MDL 0.2	10.0	No	No
Barium: Ba (ug/L) - TW	2021/01/11	160.0	1000.0	No	No
Boron: B (ug/L) - TW	2021/01/11	95.0	5000.0	No	No
Cadmium: Cd (ug/L) - TW	2021/01/11	0.008	5.0	No	No
Chromium: Cr (ug/L) - TW	2021/01/11	1.32	50.0	No	No
Mercury: Hg (ug/L) - TW	2021/01/11	<MDL 0.01	1.0	No	No

	Sample Date (yyyy/mm/dd)	Sample Result	MAC	No. of Exceedances	
				MAC	1/2 MAC
Selenium: Se (ug/L) - TW	2021/01/11	0.05	50.0	No	No
Uranium: U (ug/L) - TW	2021/01/11	2.14	20.0	No	No
Additional Inorganics					
Nitrite (mg/L) - TW	Missed	Missed	1.0	No	No
Nitrite (mg/L) - TW	2021/04/06	0.006	1.0	No	No
Nitrite (mg/L) - TW	2021/07/06	0.004	1.0	No	No
Nitrite (mg/L) - TW	2021/10/04	<MDL 0.003	1.0	No	No
Nitrate (mg/L) - TW	Missed	Missed	10.0	No	No
Nitrate (mg/L) - TW	2021/04/06	0.008	10.0	No	No
Nitrate (mg/L) - TW	2021/07/06	0.009	10.0	No	No
Nitrate (mg/L) - TW	2021/10/04	0.01	10.0	No	No
Fluoride (mg/L) - TW	2018/01/09	0.26	1.5	No	No
Sodium: Na (mg/L) - TW	2018/01/16	26.5	20*	Yes	Yes

*There is no "MAC" for Sodium. The aesthetic objective for sodium in drinking water is 200 mg/L. The local Medical Officer of Health should be notified when the sodium concentration exceeds 20 mg/L so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.

Schedule 15 Sampling:

The Schedule 15 Sampling is required under O.Reg 170/03. This system is under reduced sampling. No plumbing samples were collected.

Distribution System	Number of Sampling Points	Number of Samples	Range of Results		MAC (ug/L)	Number of Exceedances
			Minimum	Maximum		
Alkalinity (mg/L)	2	8	247	260	N/A	N/A
pH	2	8	7.23	7.82	N/A	N/A
Lead (ug/l)	2	6	0.07	0.20	10	0

Organic Parameters

These parameters are tested annually as a requirement under O. Reg. 170/03. In the event any parameter exceeds half the maximum allowable concentration the parameter is required to be sampled quarterly.

- MAC = Maximum Allowable Concentration as per O. Reg. 169/03
- <MDL = Less than Method Detection Limit

	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Number of Exceedances	
				MAC	1/2 MAC
Treated Water					
Alachlor (ug/L) - TW	2021/01/11	<MDL 0.02	5.0	No	No
Atrazine + N-dealkylated metabolites (ug/L) - TW	2021/01/11	<MDL 0.01	5.0	No	No
Azinphos-methyl (ug/L) - TW	2021/01/11	<MDL 0.05	20.0	No	No
Benzene (ug/L) - TW	2021/01/11	<MDL 0.32	1.0	No	No
Benzo(a)pyrene (ug/L) - TW	2021/01/11	<MDL 0.004	0.01	No	No
Bromoxynil (ug/L) - TW	2021/01/11	<MDL 0.33	5.0	No	No
Carbaryl (ug/L) - TW	2021/01/11	<MDL 0.05	90.0	No	No

	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Number of Exceedances	
				MAC	1/2 MAC
Carbofuran (ug/L) - TW	2021/01/11	<MDL 0.01	90.0	No	No
Carbon Tetrachloride (ug/L) - TW	2021/01/11	<MDL 0.17	2.0	No	No
Chlorpyrifos (ug/L) - TW	2021/01/11	<MDL 0.02	90.0	No	No
Diazinon (ug/L) - TW	2021/01/11	<MDL 0.02	20.0	No	No
Dicamba (ug/L) - TW	2021/01/11	<MDL 0.2	120.0	No	No
1,2-Dichlorobenzene (ug/L) - TW	2021/01/11	<MDL 0.41	200.0	No	No
1,4-Dichlorobenzene (ug/L) - TW	2021/01/11	<MDL 0.36	5.0	No	No
1,2-Dichloroethane (ug/L) - TW	2021/01/11	<MDL 0.35	5.0	No	No
1,1-Dichloroethylene (ug/L) - TW	2021/01/11	<MDL 0.33	14.0	No	No
Dichloromethane (Methylene Chloride) (ug/L) - TW	2021/01/11	<MDL 0.35	50.0	No	No
2,4-Dichlorophenol (ug/L) - TW	2021/01/11	<MDL 0.15	900.0	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW	2021/01/11	<MDL 0.19	100.0	No	No
Diclofop-methyl (ug/L) - TW	2021/01/11	<MDL 0.4	9.0	No	No
Dimethoate (ug/L) - TW	2021/01/11	<MDL 0.06	20.0	No	No
Diquat (ug/L) - TW	2021/01/11	<MDL 1.0	70.0	No	No
Diuron (ug/L) - TW	2021/01/11	<MDL 0.03	150.0	No	No
Glyphosate (ug/L) - TW	2021/01/11	<MDL 1.0	280.0	No	No
Malathion (ug/L) - TW	2021/01/11	<MDL 0.02	190.0	No	No
Metolachlor (ug/L) - TW	2021/01/11	<MDL 0.01	50.0	No	No
Metribuzin (ug/L) - TW	2021/01/11	<MDL 0.02	80.0	No	No
MCPA (ug/L) - TW	2021/01/11	<0.12	100.0	No	No
Monochlorobenzene (Chlorobenzene) (ug/L) - TW	2021/01/11	<MDL 0.3	80.0	No	No
Paraquat (ug/L) - TW	2021/01/11	<MDL 1.0	10.0	No	No
PCB (ug/L) - TW	2021/01/11	<MDL 0.04	3.0	No	No
Pentachlorophenol (ug/L) - TW	2021/01/11	<MDL 0.15	60.0	No	No
Phorate (ug/L) - TW	2021/01/11	<MDL 0.01	2.0	No	No
Picloram (ug/L) - TW	2021/01/11	<MDL 1.0	190.0	No	No
Prometryne (ug/L) - TW	2021/01/11	<MDL 0.03	1.0	No	No
Simazine (ug/L) - TW	2021/01/11	<MDL 0.01	10.0	No	No
Terbufos (ug/L) - TW	2021/01/11	<MDL 0.01	1.0	No	No
Tetrachloroethylene (ug/L) - TW	2021/01/11	<MDL 0.35	10.0	No	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW	2021/01/11	<MDL 0.2	100.0	No	No
Triallate (ug/L) - TW	2021/01/11	<MDL 0.01	230.0	No	No
Trichloroethylene (ug/L) - TW	2021/01/11	<MDL 0.44	5.0	No	No
2,4,6-Trichlorophenol (ug/L) - TW	2021/01/11	<MDL 0.25	5.0	No	No
2-methyl-4-chlorophenoxyacetic acid (MCPA) (ug/L) - TW	2021/01/11	<MDL 0.12	100.0	No	No
Trifluralin (ug/L) - TW	2021/01/11	<MDL 0.02	45.0	No	No
Vinyl Chloride (ug/L) - TW	2021/01/11	<MDL 0.17	1.0	No	No

Distribution samples are tested quarterly for THM's and HAA's in accordance with O. Reg. 170/03.

	Sample Year	Sample Result	MAC	No. of Exceedances	
				MAC	1/2 MAC
Distribution Water					
Trihalomethane (THM): Total (ug/L) Annual Average - DW	2021	32	100.0	No	No
Haloacetic Acid (HAA): Total (ug/L) Annual Average - DW	2021	9.5	80.0	No	No

BTEX Parameters

A monitoring well was constructed adjacent to Water Street to monitor the potential migration of a petroleum products contaminated plume toward the source water/production well. Sampling of the ground water from the single purpose constructed monitoring well is conducted annually. These contaminants have not been detected since the beginning of the sampling program in 1998.

	Sample Date (yyyy/mm/dd)	Sample Result	MAC	No. of Exceedances	
				MAC	1/2 MAC
Production Well					
Benzene (ug/L) - RW	2021/05/12	<MDL 0.32	1	No	No
Ethylbenzene (ug/L) - RW	2021/05/12	<MDL 0.33	140	No	No
Toluene (ug/L) - RW	2021/05/12	<MDL 0.36	60	No	No
Xylene: Total (ug/L) - RW	2021/05/12	<MDL 0.43	90	No	No
m/p-xylene (ug/L) - RW	2021/05/12	<MDL 0.43	N/A	No	No
o-xylene (ug/L) - RW	2021/05/12	<MDL 0.17	N/A	No	No
Monitoring Well					
Benzene (ug/L) - RW	2021/05/12	<MDL 0.32	1	No	No
Ethylbenzene (ug/L) - RW	2021/05/12	<MDL 0.33	140	No	No
Toluene (ug/L) - RW	2021/05/12	<MDL 0.36	60	No	No
Xylene: Total (ug/L) - RW	2021/05/12	<MDL 0.43	90	No	No
m/p-xylene (ug/L) - RW	2021/05/12	<MDL 0.43	N/A	No	No
o-xylene (ug/L) - RW	2021/05/12	<MDL 0.17	N/A	No	No

Additional Legislated Samples

Schedule C: System-Specific Conditions of Municipal Drinking Water License #259-101 requires the Killaloe Drinking Water System to monitor the effluent discharged to the natural environment.

Legal Document	Date of Issuance	Parameter	Limit	Result	Unit of measure
MDWL #259-101	30-Nov-2020	Backwash Effluent Suspended Solids	Annual Avg < 15 mg/L	3.10	mg/L
		Backwash Effluent pH	Annual Avg 6.5-8.5	8.00	N/A
		Backwash Effluent Total Chlorine Residual	Annual Avg < 0.02 mg/L	0.03	mg/L

Schedule D: Conditions for Relief from Regulatory Requirements of Municipal Drinking Water License #259-101 requires the Killaloe Drinking Water System to monitor the distribution system for the following parameters for using Huwa-San NSF Certified Stabilized Hydrogen Peroxide as a disinfectant.

Legal Document	Date of Issuance	Parameter	Date Sampled	Result	Unit of measure
MDWL #259-101	30-Nov-2020	Distribution pH	2021/01/11	7.17	N/A
			2021/07/06	7.55	N/A
		Distribution Copper	2021/01/11	64.2	ug/L
			2021/07/06	0.14	ug/L
		Distribution Lead	2021/01/11	164	ug/L
			2021/07/06	0.07	ug/L

See Distribution Peroxide Residuals in the “Operational Testing” section of this report for data of hydrogen peroxide residuals using a continuous monitoring analyzer, weekly grab samples, and from grab samples collected at the same time as a microbiological sample as required by the Municipal Drinking Water Licence.

Evaluation of the Effectiveness of Secondary Disinfectant

The hydrogen peroxide continues to work well as a secondary disinfectant while producing reduced THM's and HAA's within the distribution system. There have been no significant anomalies in any tested levels. The trend in past years of HPC results that are unusually high on approximately a yearly basis did not occur in 2021, with the highest HPC result found to be 22 cfu/mL. Though, there was no evidence to the high HPC results occurring in regards to the hydrogen peroxide residual taken at the time of sample.

There were no events of observations made under Section 16-4 (Duty to Report Other Observations) where hydrogen peroxide residuals were below 0.5 mg/L in the treated water or in the distribution system. The maximum hydrogen peroxide residual exceeded 8 mg/L in distribution system on March 5th 2021 from 20:22:00 to 23:22:00 for a total of three hours. Operations staff received an alarm for High Distribution H₂O₂ and found the analyzer feed line to be airlocked. The air was flushed from the line and the analyzer began to read 4.8 mg/L once the air was removed. It should be noted that the hydrogen peroxide residual in the treated water leaving the water treatment plant did not exceed 6.60 mg/L.

Major Maintenance Summary

WO #	Description
2094029	Flash mixer unit refurbished
2173352	Clean and inspect clearwell #1, clearwell #2, and pump chambers
2175283	Replace well level pressure probe
2579440	Replace Post UV H ₂ O ₂ analyzer sample cell block
2497107	Replace chlorine dosing chemical line

Appendix A

WTRS Data and Submission Confirmation



Location: [WTRS](#) / [WT DATA](#) / [Input WT Record](#)

WTRS-WT-008

Water Taking Data submitted successfully.

Confirmation:

Thank you for submitting your water taking data online.

Permit Number: 2835-9LMRUZ

Permit Holder: THE CORPORATION OF THE TOWNSHIP OF KILLALOE, HAGARTY AND RICHARDS.

Received on: Feb 11, 2022 3:08 PM


This confirmation indicates that your data has been received by the Ministry, but should not be construed as acceptance of this data if it differs from that specified on the Permit Number, assigned to the Permit Holder stated above.

[Return to Main Page](#)

KAYLEE SAAR | 2022/02/11

version: v4.5.0.21 (build#: 22)

Last modified: 2018/09/18



This site maintained by
the Government of Ontario

©2022 [Queen's Printer for Ontario](#)