

Killaloe Wastewater System

Annual Report

Prepared For: The Township of Killaloe, Hagarty and Richards

Reporting Period of January 1st – December 31st 2021

Issued: March 16th, 2022

Revision: 0

Operating Authority:



This report has been prepared as a general summary of results and events. The Certificate of Approval governing this facility does not require an annual report to be prepared, or define effluent objectives and limits. It is there by operated based solely on provincial guidelines.

Table of Contents

Operations and Compliance Reliability Indices	1
System Process Description.....	1
Flows.....	2
Raw Flows	2
Effluent Flow.....	2
Raw Sewage Quality	3
BOD5 Influent Monthly Average Concentration (mg/L).....	3
Total Suspended Solids Influent Monthly Average Concentration (mg/L).....	4
Total Phosphorus Influent Monthly Average Concentration (mg/L).....	4
Total Ammonia Nitrogen Influent Monthly Average Concentration (mg/L)	5
pH Influent Monthly Average	5
Effluent Quality Assurance or Control Measures	6
Effluent Quality	6
Carbonaceous Biochemical Oxygen Demand (5-Day)	7
Total Suspended Solids.....	8
Total Phosphorus.....	9
Total Ammonia Nitrogen	10
<i>E.Coli</i>	11
pH.....	11
Operating Issues	12
Major Maintenance Summary.....	12
Flow Meter Calibrations and Maintenance	12
Maintenance Summary	12
Notice of Modifications	12
Sludge Generation	13
Sludge Disposal Summary.....	13
Annual Sludge Disposal Comparison (m3/year)	13
Summary of Complaints.....	14

Summary of Abnormal Discharge Events	14
Bypass/Overflow/Spills.....	14
Biosolids Quality Report	A
Flow Meter Calibration Records	B

Operations and Compliance Reliability Indices

Compliance Event	# of Events
Ministry of Environment Inspections	1 MECP Inspection on September 14 th 2021
Ministry of Labour Inspections	0
Environment Canada Inspections	0
Non-Compliance	0 - see Operating Issues for details
Bypass/Overflows/Spills	0 / 0 / 0
Community Complaints	1 - see Summary of Complaints for details
Sewer Main Blockages	0

System Process Description

The Killaloe Wastewater Treatment System consists of a sewage treatment plant and one sewage pumping station. In the event of a power failure, emergency power is supplied from the main treatment facility to the pumping station. Wastewater from the Village of Killaloe is collected at the Henry Street pumping station, and is then pumped to the Class II Wastewater Treatment Facility located at 113 Keetch Street. Upon entering the facility the incoming wastewater receives primary treatment consisting of two grit removal channels equipped with two proportional weirs, an emergency by-pass bar screen, and a three inch Parshall Flume for measuring influent flows.

Secondary treatment is achieved through the Extended Aeration Process consisting of a comminutor, an aeration chamber with fine bubble aeration, a clarifier with chemical addition of PAS-8 for phosphorus removal, and an aerated sludge holding tank/digester. The activated sludge which settles to the bottom of the clarifier is either returned to the head of the aeration tank or is diverted to the digester. Bio-solids are aerobically digested, stored on site and later land applied under the Nutrient Management Act.

The clear effluent overflows the clarifier weirs and is collected in the channel leading to the chlorine contact chamber. Disinfection is achieved in the contact chamber by the addition of sodium hypochlorite prior to being de-chlorinated with sodium sulfite pucks before discharging into Brennan's Creek and ultimately Golden Lake.


The addition of two chemical dosing pumps each with a capacity of 30 L/hr, dosing calcium thiosulfate to the 12 inch diameter outfall sewer is scheduled to be installed in the summer of 2022 for a permanent de-chlorinating solution.

Flows

The annual average daily flow for 2021 was 347 m³/d, which represents 66% of the facility's 518 m³/d rated capacity.


Raw Flows

2021 Raw Flows




Effluent Flow

2021 Effluent Flow




Annual Effluent Flow Comparison




Raw Sewage Quality


BOD5 Influent Monthly Average Concentration (mg/L)




Total Suspended Solids Influent Monthly Average Concentration (mg/L)




Total Phosphorus Influent Monthly Average Concentration (mg/L)



Total Ammonia Nitrogen Influent Monthly Average Concentration (mg/L)



pH Influent Monthly Average



Effluent Quality Assurance or Control Measures

Effluent control measures include in-house sampling and testing for operational parameters such as suspended solids, pH, total chlorine, soluble phosphorus, and dissolved oxygen. In-house testing provides real time results which are then used to enhance process and operational performance. All in-house sampling and analysis is performed by certified operations staff utilizing approved methods and protocols for sampling, analysis and recording as specified in the Ministry's Procedure F-10-1, *Procedures for Sampling and Analysis Requirements for Municipal and Private Sewage Treatment Works*; the Ministry's publication, *Protocol for the Sampling and Analysis of Industrial/Municipal Wastewater*; and the publication, *Standard Methods for the Examination of Water and Wastewater*.

All final effluent samples collected during the reporting period to meet the Ministry's sampling requirements were submitted to SGS Lakefield Research Ltd. laboratory in Lakefield, Ontario for analysis, with the exception of pH, and temperature. The pH and temperature parameters were analyzed in the field at the time of sample collection by certified operators, to ensure accuracy and precision of the results obtained. SGS Lakefield Research has been deemed accredited by the Canadian Association for Laboratory Accreditation (CALA), meeting strict provincial guidelines including an extensive quality assurance/quality control program. By choosing this laboratory, the Ontario Clean Water Agency is ensuring appropriate control measures are undertaken during sample analysis.

Effluent Quality


There are no effluent limits defined in the Certificate of Approval for this facility. This facility operates to ensure current provincial guidelines are not exceeded, see the operating issues section of this report for further details.

The Federal Government also regulates the effluent flow, and the monthly average CBOD and suspended solids in the effluent under the Federal Fisheries Act. The results are submitted to Environment and Climate Change Canada's effluent regulatory reporting information system, under wastewater systems effluent regulations (WSER) on a quarterly basis.


Effluent results from the Killaloe wastewater treatment facility for 2021 are tabulated below.

Carbonaceous Biochemical Oxygen Demand (5-Day)

CBOD5 Effluent Monthly Average Concentration




CBOD5 Monthly Average Loading




Total Suspended Solids

TSS Effluent Monthly Average Concentration




TSS Monthly Average Loading




Total Phosphorus

TP Effluent Monthly Average Concentration




TP Monthly Average Loading




Total Ammonia Nitrogen

TAN Effluent Monthly Average Concentration



Note: There is no guideline limit on Total Ammonia Nitrogen

TAN Monthly Average Loading



Operating Issues

The Killaloe WPCP operated very well during 2021, though there was one sample collected on October 5th 2021 that lead to an exceedance of the Ministry’s *E.Coli* monthly geometric mean density (GMD) guideline of 200 CFU/100 mL. As the Killaloe WPCP Certificate of Approval does not have defined effluent limits, the GMD exceedance is considered a guideline non-conformance and is not reportable to the Ministry.

Date	Exceedance of	Value	Details
October 2021	Ministry’s Guideline: F-5 Levels of Treatment for Municipal and Private Sewage Treatment Works Discharging to Surface Waters, <i>E.Coli</i> monthly geometric mean density (GMD) guideline of 200 CFU/100 mL	1080 CFU/100 mL	Suspected additional bacterial load from sanitary system flushing before sampling occurred

Major Maintenance Summary

Flow Meter Calibrations and Maintenance

Copies of the flow meter calibration certificates for 2021 are attached in Appendix B.

Effluent Flow Meter

Calibration of the effluent flow meter was completed May 12th, 2021 by Franklin Empire.

Maintenance Summary

WO#	Details
2091322	Repaired PAS-8 pump, diaphragm was leaking
2224169	Replaced Henry Street Pumping Station Pump #1
2314351	Replaced chlorine dosing line to contact chamber

Notice of Modifications

Date	Process	Modification	Status
December 3, 2021	Disinfection	Received MECP approval to install a 310 Liter double wall polyethylene storage tank and two chemical dosing pumps each with a capacity of 30 L/hr to dose Calcium Thiosulfate to the 12 inch diameter outfall sewer of the wastewater treatment plant for de-chlorinating the treated effluent	Scheduled to be installed in summer of 2022


Sludge Generation

Sludge Disposal Summary

In 2021, a total of 360 m³ of liquid bio-solids was hauled offsite by Terrapure Organics Solutions and utilized as soil conditioner or hauled to processing facility. It is anticipated that approximately the same volume of sludge will be generated in 2022.

Date	Landowner / Disposal Location	NASM # / ECA #	Total Volume (m3)
05/12/2021	Trotter - Graham	23904	80
05/13/2021	Trotter - Graham	23904	40
09/13/2021	Parks, David - Home	24817	120
10/26/2021	Terrapure Storage Facility	S-3708-42	80
10/27/2021	Terrapure Storage Facility	S-3708-42	40
Total Annual Volume (m3)			360

Annual Sludge Disposal Comparison (m3/year)



Summary of Complaints

Location	Date	Nature of Complaint	Actions Taken
9 William Street	June 2 nd 2021	Sewer Back-Up	Customer's toilet had overflowed during scheduled sewer flushing to remove blockage in maintenance hole #35-4. OCWA staff confirmed no damage occurred within the home

Summary of Abnormal Discharge Events

Bypass/Overflow/Spills

No bypass, overflow or spill events during reporting period.

Appendix A

Biosolids Quality Report

Ontario Clean Water Agency
 Biosolids Quality Report - Liquid
 Digester Type: AEROBIC
Metals and Criteria

Facility: KILLALOE WASTEWATER TREATMENT FACILITY
 Works: 5539
 Period: 01/01/2021 to 12/31/2021

Note: all parameters in this report will be derived from the Bslq Station

Month	Arsenic (mg/L)	Cadmium (mg/L)	Cobalt (mg/L)	Chromium (mg/L)	Copper (mg/L)	Mercury (mg/L)	Molybdenum (mg/L)	Nickel (mg/L)	Lead (mg/L)	Selenium (mg/L)	Zinc (mg/L)
Site	KILLALOE WASTEWATER TREATMENT FACILITY										
Station	Bslq Station only										
Parameter Short Name	As	Cd	Co	Cr	Cu	Hg	Mo	Ni	Pb	Se	Zn
T/s	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean
Jan	0.100	0.020	0.040	0.290	32.000	0.006	0.150	0.400	0.400	0.100	14.000
Feb	0.100	0.020	0.040	0.360	40.000	0.010	0.140	0.430	0.400	0.100	14.000
Mar	0.100	0.026	0.040	0.330	35.000	0.006	0.160	0.420	0.500	0.100	16.000
Apr	0.100	0.020	0.040	0.300	32.000	0.006	0.150	0.410	0.400	0.100	14.000
May	0.100	0.028	0.040	0.330	35.000	0.011	0.180	0.440	0.500	0.100	16.000
Jun	0.100	0.025	0.040	0.370	37.000	0.010	0.170	0.450	0.500	0.100	17.000
Jul	0.100	0.015	0.030	0.220	22.000	0.008	0.100	0.310	0.300	0.100	11.000
Aug	0.100	0.019	0.040	0.270	26.000	0.008	0.120	0.360	0.300	0.100	13.000
Sep	0.100	0.019	0.040	0.300	31.000	0.007	0.180	0.350	0.300	0.100	15.000
Oct	0.100	0.022	0.040	0.240	27.000	0.006	0.120	0.320	0.300	0.100	12.000
Nov	0.100	0.014	0.040	0.260	28.000	0.005	0.120	0.360	0.400	0.100	13.000
Dec	0.100	0.019	0.050	0.310	36.000	0.005	0.120	0.400	0.400	0.100	15.000
Average	0.100	0.021	0.040	0.298	31.750	0.007	0.143	0.388	0.392	0.100	14.167
Max. Permissible Metal Concentrations (mg/kg of	170.000	34.000	340.000	2,800.000	1,700.000	11.000	94.000	420.000	1,100.000	34.000	4,200.000
Metal Concentrations in Sludge (mg/kg)	3.997	0.823	1.599	11.925	1,269.154	0.293	5.696	15.490	15.656	3.997	566.289

Appendix B

Flow Meter Calibration Records



CALIBRATION REPORT

Report No.: OCWA CP21

Date: 12-May-21

SITE: Killaloe WWTP
PROCESS AREA: WWTP
INSTR. TAG:
MANUFACTURER: Siemens
MODEL: OCM III
SERIAL No.: 05020703102XV
OCWA Code: 0000191515

SERVICE DATE: May 12, 2021

TECHNICIAN: Mike Humphries

JOB REFERENCE: OCWA CP'21

Input (Test)		Output (Signal)		Output (Process)		
Type:	Head meters	Type or EGU:	mA	L/s	m3/day	
Min:	0.0000	Min:	0.00	0.00	0.00	
Max:	0.3503	Max:	34.72	34.72	3000.00	
Weir Width (in.)	3	Parshall Flume				
exponent	1.55				1.547	
constant	176.5000					
			Before Calibration		After Calibration	
Input (m)	Calc flow (l/s)	Calc. O/P (m3/d)	Output (m3/day)	%Error	Output (m3/day)	%Error
0.000	0.000	0.00	0.00	0.00%	0.00	0.00%
0.100	4.974	429.79	427.47	-0.54%	422.00	-1.81%
0.200	14.566	1258.51	1244.47	-1.12%	1275.00	1.31%
0.350	34.678	2996.15	2999.63	0.12%	3019.00	0.76%

Calibration Equipment			
Type:	Spare transducer	DMM	Tape Measure
Manufacturer:		Fluke	
Model:		Model 87	
Serial No.:		94140067	
Last Cal. Date:		March 19, 2021	

Comments: TOT: 2253949
 4mA=4.03, 8.00=8.02,12.02,16.01,20.02

AS FOUND: **PASS**

AS LEFT: **PASS**

CERTIFIED BY: Mike Humphries